

LUBRICATION
ORDER

7 OCTOBER 1975 (Supersedes L05-6115-293-12 Dtd 21 FEB 1961)

L05-6115-293-12

GENERATOR SET, DIESEL ENGINE: PRECISE POWER; 100 KW,
AC, 120/208 V, 60 CYCLE, 240/416 V, 50 CYCLE; SKID
MOUNTED (DETROIT DIESEL DIVN. GENERAL
MOTORS CORP.MDL.6910A)W/GENERAL MOTORS
ENGINE MODEL 6910A, SERIES 6-71

Reference: FEDERAL SUPPLY CATALOG C9100-IL

WARNING

Intervals are based on normal hours of operation. Adjust to compensate for abnormal operation and severe conditions or contaminated lubricants. During inactive periods, sufficient lubrication must be performed for adequate preservation.

Clean fittings before lubricating

Relubricate after washing

Drain crankcase only when hot after operation; replenish and check level when cool.

Dry cleaning solvent, P-D-680, used to clean ports is potentially dangerous to personnel and property. Avoid repeated and prolonged skin contact. Do not use near open flame or excessive heat. Flash point of solvent is 100 degrees F. (38° C.) - 138 degrees F. (59° C.).

Clean parts with SOLVENT, dry-cleaning (Federal Specification P-D-680). Dry before lubricating.

* The time specified is the time required to perform all services at the particular interval.

* TOTAL MAN-HR		* TOTAL MAN-HR	
INTERVAL	MAN-H	INTERVAL	MAN-HR
10	0.5	300	1.0
250	0.5	500	0.5
		2000	0.5

FOLD

FOLD

LUBRICANT • INTERVAL

INTERVAL • LUBRICANT

