

LUBRICATION ORDER

22 February 1989

(Supersedes LO 5-4610-205-12 23 May 1978)

**WATER PURIFICATION UNIT: BASE MOUNTED; ELECTRIC DRIVEN,
AC, 115, 208 VOLT, SINGLE PHASE AND 3 PHASE,
60 CYCLE; 3000 GALLON PER HOUR
(MET-PRO MODEL 3000-2700A)**

Reference: C9100-IL

Approved for public release; distribution is unlimited

Intervals and related task-hour times are based on normal hours of operation. The task-hour time specified is the time you need to do all the services prescribed for a particular interval. Change the interval if your lubricants are contaminated or if you are operating the equipment under adverse operating conditions, including longer than usual operating hours. You may extend the interval during periods of low activity, but you must take adequate preservation precautions.

•The time specified is the time required to perform all the particular interval.

Clean fittings before lubricating. Lubricate points indicated by dotted arrow shaft on both sides of

equipment. Clean parts with drycleaning SOLVENT(SD), type II or equivalent. Dry before lubricating. Drain gear case when HOT. Fill and check level. The lowest level of maintenance authorized to lubricates a point is indicated by one of the following: (C) Operator/Crew, (O) Organizational Maintenance.

You can help improve this manual. If you find any mistakes or if you know of a way to improve the procedures, please let us know. Mail your letter or DA Form 2028 (Recommended Changes to Publications and Blank Forms) Direct to: Commander US Army Troop Support Command, ATTN: ARMSTRMCTS 4300 Goodfellow Blvd. St. Louis, MO 63120-1798. A reply will be furnished to you.

*TOTAL TASK-HR		*TOTAL TASK-HR	
INTERVAL	TASK-HR	INTERVAL	TASK-HR
10	0.4	500	0.4
50	0.7	1000	0.4
250	0.1		

